

## Pump House Generator Project Q&A

1) Ground stability for the structure to be built. Response: Ground conditions will support structure

2) Is Rigid steel required inside? Response: EMT can be used indoors

3) Gas pressure : Response: To the best of the engineers knowledge, the outlet gas pressure to the building gas regulator is 14" wc (0.5 psi). The existing generator has a 6.5" wc regulator. The existing building regulator is assumed to have mislabeled units of pressure output stamped on it, i.e. ½" wc versus ½ psi output. The existing gas output pressure should be sufficient for the new generator installation.

4) Fence Response: If removed, fence needs to be replaced.

Bidder's qualification form on the Town Website

Any comments you can give would be appreciated.

Dan Schofield  
DCPW Environmental Services  
Town of Union  
607.786.2979