

**WEST CORNERS SANITARY SEWER PUMP STATION REPLACEMENT
TOWN OF UNION
COUNTY OF BROOME, STATE OF NEW YORK**

March 9, 2022

ADDENDUM NO. 1

TO THE BIDDERS:

The following changes shall be made to the "Contract Plans, Contract Documents and Specifications for the "WEST CORNERS SANITARY SEWER PUMP STATION REPLACEMENT" project in the Town of Union, New York, dated January 2022.

CONTRACTOR TO NOTE RECEIPT OF THIS ADDENDUM NO. 1 ON THE PROPOSAL FORM.

ITEM 1: Advertisement

A. none

ITEM 2: Plans

A. On DWG G-001 ADD Notes –

"20. Grating on the Platform shall be able to support loads stated on structural plans based on spacing of joists, while only allowing a 3/16" or less deflection. Grating on the platform shall be non-serrated and have standard bearing bar spacing of 1-3/16, stairs shall have serrated grating. Platform Railing shall be constructed of 2" x 2" x 1/4" square tubing.

21. Submit a shop drawing of platform showing it is in general conformance with the design shown in the plans."

ITEM 3: Specifications

A. None

ITEM 4: Itemized Proposal

A. None

ITEM 5: Clarification

A. None

This Addendum No. 1 shall become part of and attached to the Contract Documents and Specifications.

FOR THE Town of Union

By: 

Shumaker Consulting Engineering and
Land Surveying. D.P.C.

Date: March 9, 2022